

# Confirmation

## LEED

On 26 January 2018, Eurofins Product Testing A/S received a sample of a joint sealant with the product name:

**Sikasil®-670 Fire**

supplied by

**Sika Technology AG**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, CDPH, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2018-00040402\_H\_EN\_02 and 392-2018-00044002\_XG\_EN\_02).

**The test results of the tested coating indicate that the product qualifies for LEED v4 specifications on VOC emissions and/or VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- the requirements of SCAQMD rule 1113 (2011).

13 April 2018

  
Paul Santner  
Consultant  
Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.