



Product Service

Attestation of Conformity

No. N8A 092292 0085 Rev. 01

Holder of Certificate: **Jiangyin Baohong Electrical Appliance Co., Ltd**NO.173,Huqiao Road, Xiagang Town
214442 Jiangyin City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA**Product:** **Sockets**
Surface type socket-outlets with a parallel connected switch**Model(s):** **BHMB-E, BHMBW-E, BHTB-1E****Parameters:**
Rated voltage: 250V~
Rated current: 16A for socket module
6A for switch module
Rated frequency: 50/60Hz
Contact opening for switch: Normal gap construction
Pattern number for switch: 1
Protection class: I
Degree of protection: IP 20 for BHMB-E, BHTB-1E
IP 44 for BHMBW-E**Remark:**

1. The degree of protection must be ensured by the installation.
2. Clause 10.5.1 (access gauge) was only assessed on the socket port. Protection from access to live parts have to be checked at openings after mounting.

Tested according to:DIN VDE 0620-1:2016/A1:2017
DIN VDE 0620-1:2021 Abschnitt 10.5
DIN VDE 0620-2-1:2016/A1:2017
DIN VDE 0620-2-1:2021 Abschnitt 10.5

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704102101606-00**Date,** 2021-12-06

(Jie Zhu)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.