

1. Unique identification code of the product-type: No-Flame 83284/83285/83286  
Photoelectric smoke alarm with lithium battery
2. Intended use: Smoke alarm intended for household or similar residential application
3. Manufactured by: HP Schou A/S  
Nordager 31  
DK – 6000 Kolding
4. System of assessment and verification of constancy of performance of the construction product as set out in Annex V: System 1
5. a) Harmonised standard EN 14604:2005/AC:2008

Notified production control certification body No 2831 performed the initial inspection of the manufacturing plant and of factory production control and the continuous surveillance, assessment and evaluation of factory production control, and issued the certificate 2831-CPR-F1390 of constancy of the factory production control

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

7. Declared performances:

Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions/ Sensitivity, Response delay (response time) and Performance under fire Condition	Pass	<b>EN 14604:2005 /AC:2008</b>
Operational reliability	Pass	
Tolerance to supply voltage	Pass	
Durability of operational reliability and response delay, temperature resistance	Pass	
Durability of operational reliability, vibration resistance	Pass	
Durability of operational reliability, humidity resistance	Pass	
Durability of operational reliability, corrosion resistance	Pass	
Durability of operational reliability, electrical stability	Pass	

8. The performance of the product identified above is in conformity with the set of declared performances. This Constancy of performance is issued , in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above:

Signed for and on behalf of the manufacturer:

Kolding 15. January 2020

  
Kirsten Vibeke Jensen/ Product safety manager