

DECLARATION OF PERFORMANCE

No. P0934

1. Unique identification code of the product-type:

Bostik Fire Bond Gap Seal+

2. Type, batch or serial number as required pursuant to Article 11(4) of CPR:

Se ETA 17/0935 & ETA 17/0936; see batch number displayed on product.

3. Intended uses in accordance with the applicable harmonised technical specification:

Fire sealing/stopping material designed for the reinstatement of linear joints/gaps and openings in fire resistant wall and floor constructions provided for the penetration of multiple services.

See ETA 17/0935 and ETA 17/0936.

4. Name and contact address as required by Article 11(5) of CPR:

Bostik AB, Strandbadsvägen 22, 251 09 Helsingborg, Sweden

5. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

Dutch Marine Systems BV., Hoogschaijkstraat 15, 5374 EC Schaijk, Nederland

6. System of assessment and verification of consistency of performance as set out in CPR, Annex V:

System 1.

7. Basis of declared performance:

European Technical Assessments ETA 17/0935 and ETA 17/0936 issued by notified body UL International (UK) Ltd. on the basis of ETAG 026-2 & ETAG 026-3. UL also performed/performs third party tasks as set out in Annex V under System 1 and have issued Certificate of Conformity 0843-CPR-0393.

8. Declared performance:

Essential Characteristics	Declared Performance	Harmonized Technical Specification
Resistance to fire	Up to EI240 depending on type of substrate, see ETA 17/0935 and ETA 17/0936	EN 13501-2; ETAG 026-2; ETAG 026-3
Release of dangerous substances	See the product SDS	N/A
Durability and serviceability	Z ₁	EOTA TR024

Signed for and on behalf of the manufacturer by:

Helsingborg 2019-01-16


 Robert Massey, CEO